

Trailer Park – Water Report

Inorganic Contaminants:								
	MCLG	MCL	Your Water	Low Range	High Range	Sample Date	Violation	Typical Source
Arsenic (ppb)	NA	50	1.3			4/10/95	No	Erosion of natural deposits. Runoff from orchards, glass and electronic production wastes.
Nitrate [measured as Nitrogen] (ppm)	10	10	0.68	0	0.68	12/28/99	No	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.
Radioactive Contaminants: Alpha emitter (p Ci/L)	0	15	1.6	0	1.6	8/12/99	No	Erosion of natural deposits.